


LAMP PHOTOMETRIC REPORT

MODEL: 99POM1505030/BL		
POWER: 50W	VOLTAGE: 230V	WORKING VOLTAGE: 230V
MANUFACTURER: Elmark Industries JSC		

TOTAL FLUX: 4664.9 lm



$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%
10	1809	1820	1825	1815	1814	1817	1827	1822	0- 10	175.8	175.8	3.77
20	1658	1690	1713	1682	1669	1684	1714	1696	10- 20	497.0	672.8	14.4
30	1432	1488	1533	1478	1447	1481	1536	1497	20- 30	734.2	1407	30.2
40	1158	1236	1303	1224	1174	1226	1306	1246	30- 40	853.2	2260	48.5
50	871.4	952.8	1039	941.2	885.2	942.8	1041	962.8	40- 50	845.4	3106	66.6
60	586.9	663.1	756.1	652.4	597.0	653.6	761.0	672.5	50- 60	725.5	3831	82.1
70	312.2	378.8	470.3	369.0	321.2	369.9	474.9	386.8	60- 70	519.4	4350	93.3
80	74.38	121.7	204.5	112.9	77.20	113.6	208.5	128.1	70- 80	266.8	4617	99
90	1.815	2.270	3.113	2.395	1.511	2.030	2.794	1.973	80- 90	47.69	4665	100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature:25.3°C  
Operators:  
Test Date:01 December 2022

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 2.5DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity:65.0%  
Test Distance:6.265m [K=1.0000]  
Remarks:



```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```